



## **ADDENDUM NO. 1**

### **EAST CRYSTAL FALLS BOULEVARD MEDIAN PLANTING PLAN**

City of Leander Parks & Recreation Department

Issued August 24, 2015

- Item No. 1**     **East Crystal Falls Boulevard Planting Plan Sheet L4 of 4 Irrigation Notes, #2** shall read “Coordinate source of water with City of Leander. Water taps are 5/8” main and are located within planting median. Power Source shall be battery powered solenoid valves.”
- Item No. 2**     **East Crystal Falls Boulevard Planting Plan Sheet L3 of 4 #1 Detail “Shrub planting details”,** Weed barrier note has been removed. No weed barrier fabric shall be used.
- Item No. 3**     **East Crystal Falls Boulevard Planting Plan Sheet L1 of 4 Plant List (Materials List)** There is approximately 685 lineal feet of steel edging that should be included in list. Edging shall be black, 3/16” gauge Sure-loc or approved commercial steel edging.

#### **General Clarifications/ Questions answered:**

1. Irrigation permit is the only permit you need for the project
2. As built drawings will need to be provided for the irrigation system.  
Bubblers will need to be installed for all zones in an inconspicuous place so that the City can make sure system is working.
3. Drip for sod areas also.
4. Chemical kill for grass on sites.

#### **Clarification/Questions for East Crystal Falls Parkway**

1. Monument signs at Crystal Falls Boulevard will be by others.
2. Traffic control in median for safety of installers should be included on the bid as separate line items.